

Report
On
Energy Audit
At
Shree H.V.P. M's Degree College Of Physical Education, Amravati.
(Year 2020-21)



Prepared by
Nutan Urja Solutions
A 703, Balaji Witefield, Near Sunni's World,
Sus Road, Sus, Pune 411 021
Phone: 83568 18381. Email: nutanurja.solutions@gmail.com

Contents

| | |
|--|----|
| Acknowledgement | 2 |
| Executive Summary | 3 |
| Abbreviations | 5 |
| 1. Introduction..... | 6 |
| 1.1 Objectives..... | 6 |
| 1.2 Audit Methodology: | 6 |
| 1.3 General Details of College | 6 |
| 2. Study of connected load..... | 7 |
| 3. Study of Electrical Energy Consumption | 11 |
| 4. Carbon Foot printing..... | 13 |
| 5. Study of usage of alternate energy..... | 15 |
| 6. Study of usage of LED lighting | 16 |
| 7. Energy conservation proposals | 17 |
| 7.1 Replacement of Old T-8 FTLs with 20 W LED fittings | 17 |
| 7.2 Replacement of old fans with STAR Rated fans..... | 18 |
| 7.3 Installation of Solar PV panel | 19 |
| 7.4 Summary of Savings | 20 |

Acknowledgement

We at Nutan Urja Solutions, Pune, express our sincere gratitude to the management of Shree H.V.P.M's Degree College Of Physical Education, Amravati for awarding us the assignment of Energy Audit of their college premises.

We are also thankful to various Head of Departments & other Staff members for helping us during the field measurements.

We hope that the recommendations stated in this report will be useful and worthy of discussions to take things forward to help implementation of energy conservation measures through energy savings. While we have made every attempt to adhere to high quality standards, in both data collection and analysis through the report, we would welcome your suggestions so as to improve upon this report further.

Executive Summary

After the Field measurements & analysis, we present herewith important observations made and various measures to reduce the Energy Consumption & mitigate the CO₂ emissions. College consumes Energy in the form of Electrical Energy used for various gadgets, Office & other facilities.

1. Present Energy Consumption

In the following Table, we present the details of Energy Consumption.

Table no 2.1: Details of energy consumption

| Sr no | Parameter | Energy consumed, (Units) | CO ₂ Emission (MT) |
|-------|-----------|--------------------------|-------------------------------|
| 1 | Maximum | 41,540 | 33.2 |
| 2 | Minimum | 11,298 | 9.0 |
| 3 | Average | 25,281 | 20.2 |
| 4 | Total | 303,366 | 242.7 |

2. Energy Conservation Projects already installed

1. Usage of STAR Rated ACs at new installations
2. Usage of LED lights at some indoor locations
3. Usage of LED Lights for outdoor lighting.

3. Key Observations

1. Usage of LED lights.
2. Usage of star rated equipment.
3. Maintained a good power factor.

4. Percentage of Usage of Alternate Energy

The College has installed a Roof Top Solar PV Plant. The percentage of usage of Alternate Energy to Annual Energy Requirement is 20 %.

5. Percentage of Usage of LED Lighting

The College has various Types of Light fittings, namely: LED, FTL & CFL. The percentage of Annual LED Lighting Usage to Annual Lighting requirement works out to be 37%.

6. Recommendations

Table no 1: Recommendations for energy savings

| No | Recommendation | Annual Saving potential, kWh/Annum | Annual Monetary Gain, Rs. | Investment Required, Rs. | Payback period, Months |
|----|---|------------------------------------|---------------------------|--------------------------|------------------------|
| 1 | Replacement of 428 Nos T-8 fittings with 20W LED fittings | 8,560 | 94,160 | 274,348 | 35 |
| 2 | Replacement of 341 Nos Old Ceiling Fans with STAR rating fans | 4,433 | 48,763 | 741,334 | 182 |
| 3 | Installation of 200kW grid connected PV panel | 300,000 | 3,300,000 | 10,000,000 | 36 |
| | Total | 312,993 | 3,442,923 | 11,015,682 | 38 |

7 Notes & Assumptions

1. Daily working hours-10 Nos
2. Annual working Days-300 Nos
3. Average Rate of Electrical Energy : **Rs 11/- per kWh**

Abbreviations

| | |
|-----|----------------------------|
| CFL | : Compact Fluorescent Lamp |
| FTL | : Fluorescent Tube Light |
| LED | : Light Emitting Diode |
| V | : Voltage |
| I | : Current |
| kW | : Kilo- Watt |
| kWh | : kilo-Watt Hour |
| kVA | : Active Power |

1. Introduction

Shree H.V.P.M's Degree College Of Physical Education, Amravati is runned by world famous institute Shree Hanuman Vyayam Prasarak Mandal. Mandal is established in 1914 and has completed more than 100 years. Mandal started the regular programme of physical education to provide trained and discipline physical education teacher by establishing this training college in the year 1967 with the permission of Government of Maharashtra in urban area at Amravati and affiliated to Nagpur University, Nagpur earlier. This is the only college in Maharashtra which started a three years degree course in physical education on govt. grant basis. This college is now permanently affiliated to Sant Gadge Baba Amravati University, Amravati.

1.1 Objectives

1. To study present level of Energy Consumption
2. To Study Electrical Consumption
3. To assess the various equipment/facilities from Energy efficiency aspect
4. To study various measures to reduce the Energy Consumption

1.2 Audit Methodology:

1. Study of connected load
2. Study of various Electrical parameters
3. To prepare the Report with various Encon measures with payback analysis

1.3 General Details of College

Table No-1.1: Details of college

| No | Head | Particulars |
|----|---------------------|--|
| 1 | Name of Institution | Shree H.V.P.M's Degree College Of Physical Education, Amravati |
| 2 | Address | Hanuman Vyayam Nagar, H.V.P. Mandal, Amravati, Maharashtra. (444605) |
| 3 | Affiliation | Sant Gadge Baba Amravati University, Amravati |

2. Study of connected load

In this chapter, we present details of various connected electrical equipment and electrical load.

Table No-2.1: Location wise study of Electrical fittings in various buildings

| No | Location | FTL (40W) | LED tube (20W) | Fan | Computers (65W) | 1.5TR Star rated AC |
|----|--------------------|--------------|----------------------|-----|--------------------|------------------------------|
| 1 | Library I | | 35 | 19 | 12 | 1 |
| 2 | Class Room 1 | 3 | | 4 | | |
| 3 | Class Room 2 | 2 | | 4 | | |
| 4 | Class Room 3 | 3 | | 4 | | |
| 5 | Class Room 4 | 3 | | 4 | | |
| 6 | Class Room 5 | 3 | | 7 | | |
| 7 | Class Room 6 | 5 | | 5 | | |
| 8 | Class Room 7 | 5 | | 6 | | |
| 9 | Class Room 8 | 5 | | 6 | | |
| 10 | Class Room 9 | 5 | | 6 | | |
| 11 | Class Room 10 | 5 | | 5 | | |
| 12 | Class Room 11 | 7 | | 7 | | |
| 13 | Class Room 12 | 7 | | 7 | | |
| 14 | Class Room 13 - 16 | 15 | | 8 | | |
| 15 | Library II | 15 | | 11 | 5 | |
| 16 | B.C. Lab | 13 | | 7 | 65 | 4 |
| 17 | Office | | | 5 | 7 | |
| 18 | Staff Room | 4 | | 4 | | |
| 19 | Meeting Hall | | | 6 | | 4 |
| 20 | Auditorium hall | 32 | | 11 | | |
| 21 | Accounts Section | 22 | | 15 | 10 | 2 |
| 22 | Principal office | | | 2 | | |
| 23 | Exam centre | 20 | | 3 | | 2 |
| 24 | IQAC Room | | | 10 | 10 | 3 |
| 25 | Passage | | | 2 | 3 | 1 |
| 26 | MCA | | | | | |
| 27 | Open Hall | 11 | | 13 | 24 | |
| 28 | Exam Office | | 2 | 1 | 1 | |
| 29 | Girls Common Room | 4 | | 2 | | |

| | | | | | | |
|----|----------------------|----|----|----|----|---|
| 30 | NSS Room | 6 | 3 | 9 | | |
| 31 | Class Room 1 | 4 | | 2 | | |
| 32 | Principal Room | 2 | 1 | 1 | | 1 |
| 33 | Computer lab | 27 | | 12 | 75 | 3 |
| 34 | Departmental Office | 4 | | 2 | 4 | 2 |
| 35 | Class Room | 2 | 2 | 5 | | |
| 36 | Department | 5 | 1 | 1 | 8 | |
| 37 | Staff Room | 1 | 1 | 2 | | |
| 38 | MCA Internet Lab | 18 | | 13 | 6 | |
| 39 | Tutorial Room | 3 | | 3 | 30 | 3 |
| 40 | Class Room 2 | 6 | | 2 | | |
| 41 | Class Room 3 | 5 | | 5 | | |
| 42 | Girls Wash Room | 2 | | | | |
| 43 | Boys Wash Room | 2 | | | | |
| 44 | Sraff Wash Room | 1 | | | | |
| 45 | Passage | 6 | | | | |
| 46 | Shooting Hall | | 20 | 7 | | |
| 47 | Gymnastic Hall | | 3 | 12 | | |
| 48 | Canteen | 10 | | 6 | | |
| 49 | Mess | 40 | | 20 | | |
| | YOGA Dept. | | | | | |
| 50 | Office 1 | 1 | 3 | 2 | | 2 |
| 51 | Office 2 | | 2 | 4 | 2 | |
| 52 | Class Room | 2 | 4 | 4 | 1 | |
| 53 | Special Room | | | 4 | | |
| 54 | Passage | 2 | | | | |
| 55 | Class Room 2 | 2 | | 1 | | |
| 56 | Class Room 3 | 2 | | 2 | | |
| 57 | Yoga Medicine | 1 | | 4 | | |
| 58 | Naturopathy Lab | 4 | | 6 | | |
| 59 | Yoga Hall | 3 | 9 | 13 | | |
| 60 | Bathroom 2 | 2 | | | | |
| 61 | Ladies Naturopathy | 6 | | 6 | | |
| 62 | Bathroom 2 | 12 | 3 | | | |
| 63 | Passage | | | | | |
| 64 | Physiotherapy | 12 | | 2 | | |
| 65 | Passage | 31 | | 2 | | |
| 66 | OPD | 1 | | 3 | | |
| | Swimming Tank | | | | | |

| | | | | | | |
|----|---------------|------------|-----------|------------|------------|-----------|
| 67 | Passage | | 9 | | | |
| 68 | Office | 2 | | 2 | 1 | |
| 69 | Changing Room | 12 | | | | |
| | Total | 428 | 98 | 341 | 264 | 28 |

Apart from above load, the college has pumps, LED focus lights, CFLs and LED focus street lights on streets and grounds. Individual fitting wise load is as under.

List of LED focus lights and pumps are as follows

Table 2.2: List of LED focus lights

| SR no | LED Lights Capacity (W) | Nos |
|--------------|--------------------------------|------------|
| 1 | 100 | 35 |
| 2 | 200 | 15 |
| 3 | 150 | 10 |

Table 2.3: List of Pumps

| Sr no | Pump Capacity (HP) | Nos |
|--------------|---------------------------|------------|
| 1 | 25 | 1 |
| 2 | 15 | 1 |
| 3 | 10 | 1 |
| 4 | 5 | 5 |
| 5 | 3 | 4 |
| 6 | 1 | 5 |
| 7 | 0.5 | 1 |

Table No 2.4: Equipment wise Connected Load

| No | Equipment | Qty | Load, W/Unit | Load, kW |
|----|------------------|-----|--------------|----------|
| 1 | Ceiling Fan | 341 | 65 | 22.2 |
| 2 | AC-New (1.5 TR) | 28 | 1838 | 51.5 |
| 3 | LED-20W | 98 | 20 | 2.0 |
| 4 | F T L-40 W | 428 | 40 | 17.1 |
| 5 | Computers | 264 | 65 | 17.2 |
| 6 | Pumps | | | 69.8 |
| 7 | LED focus lights | | | 8.0 |
| | Total | | | 187.7 |

Data can be represented in terms of PIE chart as under,




Figure 2.1: Distribution of connected load.

3. Study of Electrical Energy Consumption

In this chapter, electricity bills are studied for the analysis of electrical energy consumption.

Table no 3.1: Summary of electricity bills

| No | Month | Energy (kWh) | Bill Amount (Rs) |
|----|--------------|----------------|------------------|
| 1 | Jun-21 | 25,133 | 292,369 |
| 2 | May-21 | 30,317 | 335,354 |
| 3 | Apr-21 | 37,239 | 405,620 |
| 4 | Mar-21 | 41,540 | 444,886 |
| 5 | Feb-21 | 36,547 | 400,962 |
| 6 | Jan-21 | 32,454 | 369,037 |
| 7 | Dec-20 | 21,368 | 263,001 |
| 8 | Nov-20 | 18,060 | 233,770 |
| 9 | Oct-20 | 19,773 | 247,656 |
| 10 | Sep-20 | 11,298 | 178,747 |
| 11 | Aug-20 | 13,977 | 209,235 |
| 12 | Jul-20 | 15,660 | 224,681 |
| | Total | 303,366 | 3,605,318 |

Variation in energy consumption is as follows,




Figure 3.1: Month wise energy consumption

Monthly variation in electricity bill is as follows,




Figure 3.2: Month wise electricity bill

Key observations of electricity bill are as follows,

Table no 3.2: Key observations

| Sr no | Parameter | Energy consumed, (Units) | CO2 Emission (MT) |
|-------|-----------|--------------------------|-------------------|
| 1 | Maximum | 41,540 | 33.2 |
| 2 | Minimum | 11,298 | 9.0 |
| 3 | Average | 25,281 | 20.2 |
| 4 | Total | 303,366 | 242.7 |

4. Carbon Foot printing

1. A Carbon Foot print is defined as the Total Greenhouse Gas emissions (CO₂ emissions), emitted due to various activities. In this we compute the emissions of Carbon-Di-Oxide, by usage of the various form of Electrical Energy used by the College for performing its day to day activities

2. Basis for computation of CO₂ Emissions:

The basis of Calculation for CO₂ emissions due to Electrical Energy is as under

- 1 Unit (kWh) of Electrical Energy releases **0.8 Kg of CO₂** into atmosphere.

Based on the above Data we compute the CO₂ emissions which are being released in to the atmosphere by the College due to its Day to Day operations

We herewith furnish the details of various forms of Energy consumption as under

Table 4.1: Month wise Consumption of Electrical Energy & CO₂ Emissions

| No | Month | Energy Consumed, kWh | CO ₂ Emissions, MT |
|----|--------------|----------------------|-------------------------------|
| 1 | Jun-21 | 25,133 | 20.1 |
| 2 | May-21 | 30,317 | 24.3 |
| 3 | Apr-21 | 37,239 | 29.8 |
| 4 | Mar-21 | 41,540 | 33.2 |
| 5 | Feb-21 | 36,547 | 29.2 |
| 6 | Jan-21 | 32,454 | 26.0 |
| 7 | Dec-20 | 21,368 | 17.1 |
| 8 | Nov-20 | 18,060 | 14.4 |
| 9 | Oct-20 | 19,773 | 15.8 |
| 10 | Sep-20 | 11,298 | 9.0 |
| 11 | Aug-20 | 13,977 | 11.2 |
| 12 | Jul-20 | 15,660 | 12.5 |
| | Total | 303,366 | 242.7 |

In the following Chart we present the CO2 emissions due to usage of Electrical Energy.




Figure 4.1: Month wise CO2 Emission

5. Study of usage of alternate energy

In this Chapter, we compute the percentage of Usage of Alternate/Renewable Energy to Annual Energy Requirement of the College. The College has installed Roof Top Solar PV System. The Installed Capacity of Solar PV Plant is **50 kWp**.

Table 5.1: Computation of % Usage of Alternate Energy to Annual Energy Requirement

| No | Particulars | Value | Unit |
|----|---|---------|-----------|
| 1 | Annual Energy Purchased from MSEDCL | 303,366 | kWh/Annum |
| 2 | Energy Generated by Roof Top Solar PV System | 75,000 | kWh/Annum |
| 3 | Total Energy Requirement of College | 378,366 | kWh/Annum |
| 4 | % of Usage of Alternate Energy to Annual Energy Requirement | 20 | % |

Photograph of Solar PV plant



6. Study of usage of LED lighting

In this chapter we study the lighting system of college and compute the percentage of total load catered by LED lighting.

Table 6.1: Total lighting load

| No | Particulars | Qty | Load, W/Unit | Load, kW |
|----|--------------------------------|-----|-----------------|--------------|
| 1 | F T L-40 W | 428 | 40 | 17.12 |
| | | | | |
| | LED lighting load | | | |
| 1 | LED tube | 98 | 20 | 1.96 |
| 2 | LED focus lights | 35 | 100 | 3.5 |
| 3 | LED focus lights | 10 | 150 | 1.5 |
| 4 | LED focus lights | 15 | 200 | 3 |
| | Total LED lighting load | | | 9.96 |
| | Total Lighting load | | | 27.08 |

It can be seen that out of total lighting load 37% load is LED lighting load.

7. Energy conservation proposals

7.1 Replacement of Old T-8 FTLs with 20 W LED fittings

In the facility, there are about 428 Nos, T-8, FTL fittings with Electronic/magnetic chokes. It is recommended to install the 20 W LED Tube light fittings in place of these old T-8 fittings. In the following Table, we present the savings, investment required & payback analysis.

| No | Particulars | Value | Unit |
|----|----------------------------------|--------|-------------|
| 1 | Present Qty of T-8 fittings | 428 | Nos |
| 2 | Energy Demand of T-8 fitting | 40 | W/Unit |
| 3 | Energy Demand of 20 W LED fittin | 20 | W/Unit |
| 4 | Reduction in demad | 20 | W/Unit |
| 5 | Average Daily Usage period | 4 | Hrs/Day |
| 6 | Daily saving in Energy | 34.24 | kWh/Day |
| 7 | Annual Working Days | 250 | Nos |
| 8 | Annual Energy Saving possible | 8560 | kWh/Annum |
| 9 | Rate of Electrical Energy | 11 | Rs/kWh |
| 10 | Annual Monetary saving | 94160 | Rs/Annum |
| 11 | Cost of 20 W LED Tube | 641 | Rs/Unit |
| 12 | Investment required | 274348 | Rs lump sum |
| 13 | Simple Payback period | 35 | Months |

7.2 Replacement of old fans with STAR Rated fans

During the Audit, it was observed that there are 341 no of fans. It is recommended to replace these old fans with STAR Rated fans.

In the following Table, we present the savings, investment required & payback analysis.

| No | Particulars | Value | Unit |
|----|--|--------|-------------|
| 1 | Present Qty of Old Ceiling Fan fittings | 341 | Nos |
| 2 | Energy Demand of Old Ceiling Fan fitting | 65 | W/Unit |
| 3 | Energy Demand of STAR Rated Fan | 52 | W/Unit |
| 4 | Reduction in demad | 13 | W/Unit |
| 5 | Average Daily Usage period | 4 | Hrs/Day |
| 6 | Daily saving in Energy | 17.732 | kWh/Day |
| 7 | Annual Working Days | 250 | Nos |
| 8 | Annual Energy Saving possible | 4433 | kWh/Annum |
| 9 | Rate of Electrical Energy | 11 | Rs/kWh |
| 10 | Annual Monetary saving | 48763 | Rs/Annum |
| 11 | Cost of STAR Rated Ceiling Fan | 2174 | Rs/unit |
| 12 | Investment required | 741334 | Rs lump sum |
| 13 | Simple Payback period | 182 | Months |

7.3 Installation of Solar PV panel

It is recommended to install 200 kW solar PV panel. In the following Table, we present the savings, investment required & payback analysis.

| No | Particulars | Value | Unit |
|----|---------------------------|-----------|-------------|
| 1 | Installation of PV unit | 200 | kW |
| 2 | Energy saving | 300000 | kWh/Annum |
| 3 | Rate of electrical energy | 11 | Rs |
| 4 | Annual monetary savings | 3300000 | Rs/ Annum |
| 5 | Investment required | 10000,000 | Rs lump sum |
| 6 | Simple payback period | 36 | Months |

7.4 Summary of Savings

| No | Recommendation | Annual Saving potential, kWh/Annum | Annual Monetary Gain, Rs. | Investment Required, Rs. | Payback period, Months |
|----|---|------------------------------------|---------------------------|--------------------------|------------------------|
| 1 | Replacement of 428 Nos T-8 fittings with 20W LED fittings | 8,560 | 94,160 | 274,348 | 35 |
| 2 | Replacement of 341 Nos Old Ceiling Fans with STAR rating fans | 4,433 | 48,763 | 741,334 | 182 |
| 3 | Installation of 200kW grid connected PV panel | 300,000 | 3,300,000 | 10,000,000 | 36 |
| | Total | 312,993 | 3,442,923 | 11,015,682 | 38 |